



# GREEN CHEM LABORATORIES

## SCALE BUSTER TOWER TREATMENT

SCALE & CORROSION INHIBITOR  
FOR COOLING TOWERS



SCALE AND  
CORROSION INHIBITOR



ELIMINATES  
CARBON DEPOSITS



PROTECTS  
METAL



COMPATIBLE  
WITH BIOCIDES

NET CONTENTS: ONE GALLON (128 FL. OZ.)

### DANGER

Causes severe skin burns and eye damage. Suspected of causing cancer.

### PRECAUTIONS

Obtain special instructions before use. Do not handle until all safety precautions have been read and understood. Do not breathe mist, spray. Wash thoroughly after handling. Wear eye protection, protective clothing, protective gloves.

### FIRST AID

**IF SWALLOWED:** Rinse mouth. Do NOT induce vomiting. **IF ON SKIN (OR HAIR):** Take off immediately all contaminated clothing. Rinse skin with water/shower. Wash contaminated clothing before reuse.

**IF INHALED:** Remove person to fresh air and keep comfortable for breathing. **IF IN EYES:** Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. **IF EXPOSED OR CONCERNED:** Get medical advice/attention.

### WARNINGS

**KEEP OUT OF REACH OF CHILDREN. STORE LOCKED UP.** This product can expose you to acrylamide, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov).

For industrial and commercial use only. For additional information, see Safety Data Sheet.

Manufactured for: Green Chem Laboratories • [www.GreenChemLabs.com](http://www.GreenChemLabs.com) • 1-800-964-3151

This scale and corrosion inhibitor is specifically formulated for open recirculating cooling water systems in areas of high hardness, high alkalinity scaling waters. It contains a strong calcium carbonate crystal modifier, which prevents calcium carbonate deposition, along with a yellow metal protectant. Contains a polymer designed to inhibit scale and deposition in a wide variety of aqueous systems.

### DIRECTIONS

Dosages will depend on the characteristics of the make-up water, the permissible cycles of concentration, and a cooling towers rated tonnage versus its operational tonnage.

This product should be fed at a rate of 200 to 400 ppm (25 to 50 ounces per 1000 gallons of cooling water capacity).

It should be fed to maintain a residual molybdate test level of between 1.2 and 2.4 ppm molybdate.

It is recommended that this product should be fed on a continuous basis using a suitable treatment pump and control unit. It may be fed directly from the drum or diluted to a convenient concentration with water. It should be fed to a point in the system where it will be thoroughly mixed and evenly distributed. It should be used in conjunction with an alternating algaecide and biocide treatment program.

### DISPOSAL

Dispose of contents/container to comply with local/regional/national/ international regulations.

**NFPA® RATINGS**Health: 2; Flammability: 0; Reactivity: 0

**CONTAINS/CAS NUMBER:** Water/7732-18-5; Acrylamide-Acrylic Acid Copolymer/Proprietary; Sodium Hydroxide/1310-73-2; Amino-Methylene Phosphonic Acid/Proprietary; Proprietary/Mixture